

Action taken on the Water supply issues reported

| Date | District | Name of the Newspaper | Issues published |
|------------|-------------|-----------------------|---|
| 02.04.2026 | Kanyakumari | Dinakaran | In Manavalakurichi, a sudden burst occurred in a drinking water pipeline joint, causing flooding on the road. |



400mm MS pipe damaged on 01.04.2026 was rectified and water supply effected on 02.04.2026 under 79 coastal CWSS in Kanyakumari district

Action taken on the Water supply issues reported


| Date | District | Name of the Newspaper | Issues published |
|------------|----------|-----------------------|--|
| 03.04.2026 | Madurai | Dinamalar | Water leakage from a damaged pipeline on the Usilampatti–Vathalagundu road near Uttappanayakanur has led to accumulation in roadside ditches, causing obstruction to traffic |



300mm DI pipe line leak was rectified on **04.04.2026** under **CWSS to 867 rural habitations in Madurai District** .

Action taken on the Water supply issues reported

| Date | District | Name of the Newspaper | Issues published |
|------------|------------|-----------------------|--|
| 04.04.2026 | Thiruvarur | Dinakaran | A drinking water pipe has burst and 1,000 litres of water wasted near Muthupet |



90mm MS pipeline leak was rectified and water supply effected on 04.04.2026 under Vedaranyam CWSS in Thiruvarur district

Action taken on the Water supply issues reported

| Date | District | Name of the Newspaper | Issues published |
|------------|--------------|-----------------------|---|
| 04.04.2026 | Kallakuruchi | Dinamalar | A drinking water pipe has burst, causing water to flow on to the road |



250mm AC pipe damaged was rectified and water supply effected on 04.04.2026 under CWSS to Kallakurichi and 23 others Habs in Kallakurichi Dt

Action taken on the Water supply issues reported

| Date | District | Name of the Newspaper | Issues published |
|------------|----------|-----------------------|--|
| 07.04.2026 | Karur | Dinakaran | At Thogaimalai, the Cauvery drinking water pipe is damaged and water is being wasted |



50mm GI pipe damaged on 06.04.2026 was rectified and water supply effected on 07.04.2026 under CWSS to Manaparai Municipality & 2 way side habitations in Trichy district and 48 other habitations in Karur district.

Action taken on the Water supply issues reported

| Date | District | Name of the Newspaper | Issues published |
|------------|----------|-----------------------|--|
| 09.04.2026 | Tiruppur | Dinamalar | A pipe has burst in a trench dug for cable laying, leading to wastage of drinking water. |



350mm DI pipe damaged on 09.04.2026 was rectified and water supply effected on 10.04.2026 under CWSS to 165 rural habitations in 10 village panchayats of Tiruppur union in Tiruppur district

Action taken on the Water supply issues reported

| Date | District | Name of the Newspaper | Issues published |
|------------|-------------|-----------------------|--|
| 15.04.2026 | Krishnagiri | Dinamalar | Pipeline damage, drinking water is being wasted near Branch library in Bargur TP |



200mm AC pipe line leak was rectified on 17.04.2026 under CWSS to Bargur TP and 25 other habitations

Action taken on the Water supply issues reported

| Date | District | Name of the Newspaper | Issues published |
|------------|------------|-----------------------|--|
| 16.04.2026 | Coimbatore | Dinathanthi | Broken drinking water pipeline flowing like a stream near Kinathukadavu. |



600mm DI pipe line leak was rectified and water supply effected on 16.04.2026 under CWSS to Kurichi, Kuniamuthur in Coimbatore corporation and Kinathukadavu T.P. in Coimbatore District